## **SIEMENS**

## **Data sheet**

## 6ES7134-6PA21-0BU0



SIMATIC ET 200SP, analog input module, Al Energy Meter RC ST, for Rogowski coils or current/voltage transformer 333 mV, suitable for BU type U0, channel diagnostics

General information	
Product type designation	Al Energy Meter RC ST
Firmware version	V8.0
<ul> <li>FW update possible</li> </ul>	Yes
usable BaseUnits	BU type U0
Color code for module-specific color identification plate	CC20
Supported power supply systems	TT, TN, IT
Product function	
<ul> <li>Voltage measurement</li> </ul>	Yes
<ul> <li>— without voltage transformer</li> </ul>	Yes
<ul> <li>— with voltage transformer</li> </ul>	Yes
Current measurement	Yes; max. 3 + neutral conductor
<ul> <li>— without current transformer</li> </ul>	No
<ul> <li>— with current transformer</li> </ul>	No
— With Rogowski coil	Yes
<ul> <li>With current-voltage-converter</li> </ul>	Yes; 333 mV interface
Energy measurement	Yes
<ul> <li>Frequency measurement</li> </ul>	Yes
<ul> <li>Power measurement</li> </ul>	Yes
<ul> <li>Active power measurement</li> </ul>	Yes
Reactive power measurement	Yes
<ul> <li>Power factor measurement</li> </ul>	Yes
Active factor measurement	Yes
<ul> <li>Reactive power compensation</li> </ul>	Yes
Line analysis	No
● I&M data	Yes; I&M0 to I&M3
<ul> <li>Isochronous mode</li> </ul>	No
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	STEP 7 V16 or higher with HSP
<ul> <li>STEP 7 configurable/integrated from version</li> </ul>	Configurable via GSD file
<ul> <li>PROFIBUS from GSD version/GSD revision</li> </ul>	One GSD file each, Revision 3 and 5 and higher
<ul> <li>PROFINET from GSD version/GSD revision</li> </ul>	V2.3
Operating mode	
Switching between operating modes in RUN	Yes; For module version 32 I/20 Q, it is possible to dynamically switch between 25 user data variants, 23 of which are pre-defined and 2 of which can be defined by the specific user
<ul> <li>Cyclic measured value access</li> </ul>	Yes
<ul> <li>Acyclic measured value access</li> </ul>	Yes
<ul> <li>Fixed measured value sets</li> </ul>	Yes

Freely definable measured value sets	Yes; For cyclic and acyclic measured value access
CiR - Configuration in RUN	
Reparameterization possible in RUN	Yes
Calibration possible in RUN	Yes
Installation type/mounting	
Mounting position	any
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	2010
Current consumption (rated value)	12.5 mA
Current consumption, max.	17 mA
Power loss	
Power loss, typ.	400 mW; 3x 230 V AC
Address area	400 HWV, 3X 230 V AO
Address space per module  • Inputs	256 byte
Outputs	20 byte
Hardware configuration	20 byte
Automatic encoding	Yes
3	Yes
<ul><li>Mechanical coding element</li><li>Type of mechanical coding element</li></ul>	
Selection of BaseUnit for connection variants	type C
2-wire connection	BU type U0
Time of day	во туре об
Operating hours counter	Yes
• present	TES
Analog inputs	50 may Time for any intention data of all management and adjusted
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
	values (cyclic und acyclic data)
Cable length  • shielded, max.	values (cyclic und acyclic data)  200 m
Cable length	values (cyclic und acyclic data)
Cable length  • shielded, max.  • unshielded, max.	values (cyclic und acyclic data)  200 m
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs	values (cyclic und acyclic data)  200 m  200 m
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.	values (cyclic und acyclic data)  200 m
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information	values (cyclic und acyclic data)  200 m  200 m
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes  Yes  Yes  Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes  Yes  Yes, Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage  • Hardware interrupt lost	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage  • Hardware interrupt lost  • Parameter assignment error	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage  • Hardware interrupt lost  • Parameter assignment error  • Module fault	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage  • Hardware interrupt lost  • Parameter assignment error  • Module fault  • Channel not available  • Overflow/underflow  • Overload current  Diagnostics indication LED	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt  Diagnoses  • Supply voltage  • Hardware interrupt lost  • Parameter assignment error  • Module fault  • Channel not available  • Overflow/underflow  • Overload current  Diagnostics indication LED  • Monitoring of the supply voltage (PWR-LED)	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED • Monitoring of the supply voltage (PWR-LED) • Channel status display	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max. • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED • Monitoring of the supply voltage (PWR-LED) • Channel status display • for channel diagnostics	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max. • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED  • Monitoring of the supply voltage (PWR-LED) • Channel status display • for channel diagnostics • for module diagnostics	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED  • Monitoring of the supply voltage (PWR-LED) • Channel status display • for channel diagnostics • for module diagnostics Integrated Functions	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED • Monitoring of the supply voltage (PWR-LED) • Channel status display • for channel diagnostics • for module diagnostics Integrated Functions  Measuring functions	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Cable length  • shielded, max.  • unshielded, max.  Analog value generation for the inputs  Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses  • Supply voltage • Hardware interrupt lost • Parameter assignment error • Module fault • Channel not available • Overflow/underflow • Overload current  Diagnostics indication LED  • Monitoring of the supply voltage (PWR-LED) • Channel status display • for channel diagnostics • for module diagnostics Integrated Functions	values (cyclic und acyclic data)  200 m  200 m  2 048 kHz  Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

<ul> <li>Type of measured value acquisition</li> </ul>	seamless
Curve shape of voltage	Sinusoidal or distorted
<ul> <li>Buffering of measured variables</li> </ul>	Yes
Parameter length	128 byte
Bandwidth of measured value acquisition	3.2 kHz; Harmonics: 63 / 50 Hz, 52 / 60 Hz
Measuring range	
<ul> <li>Frequency measurement, min.</li> </ul>	40 Hz
<ul> <li>Frequency measurement, max.</li> </ul>	70 Hz
Measuring inputs for voltage	
<ul> <li>Measurable line voltage between phase and neutral conductor</li> </ul>	277 V
<ul> <li>Measurable line voltage between the line conductors</li> </ul>	480 V
<ul> <li>Measurable line voltage between phase and neutral conductor, min.</li> </ul>	3 V
<ul> <li>Measurable line voltage between phase and neutral conductor, max.</li> </ul>	300 V
<ul> <li>Measurable line voltage between the line conductors, min.</li> </ul>	6 V
<ul> <li>Measurable line voltage between the line conductors, max.</li> </ul>	519 V
<ul> <li>Internal resistance line conductor and neutral conductor</li> </ul>	1.5 ΜΩ
<ul> <li>Power consumption per phase</li> </ul>	60 mW; 300 V AC
<ul> <li>Impulse voltage resistance 1,2/50μs</li> </ul>	2.5 kV
Overvoltage category	CAT II according to IEC 61010 Part 1
Measuring inputs for current (Rog. or I/U converter)	,
Measurable current at AC, max.	424 mV
<ul> <li>Continuous voltage, maximum permissible</li> </ul>	2 V
Rated value, short-time withstand voltage restricted to 1 s	30 V
— Input resistance	120 kΩ
— Zero point suppression	Yes; 0 20%, referred to the nominal current
Accuracy class according to IEC 61557-12	
Measured variable voltage	0,2
Measured variable current	0,2
<ul> <li>Measured variable apparent power</li> </ul>	0.5
Measured variable active power	0.5
Measured variable reactive power	1
Measured variable power factor	0.5
Measured variable active energy	0.5
Measured variable reactive energy	1
Measured variable reactive energy      Measured variable neutral current	0,2
Measured variable phase angle	±0.5°; not covered by IEC 61557-12
Measured variable frequency	0.05; only valid for the permissible voltage measuring range
Potential separation	
Potential separation channels	
between the channels	No
between the channels and backplane bus	Yes
Between the channels and load voltage L+	Yes; Including FE
Isolation	
Isolation tested with	Between channels and backplane bus, 24 V supply: Routine test, 1 920 V AC, 2 s; between backplane bus and 24 V supply: Type test, 707 V DC
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-30 °C
horizontal installation, min.     horizontal installation, max.	-50 °C
vertical installation, min.	-30 °C
· · · · · · · · · · · · · · · · · · ·	-30 °C
vertical installation, max.  Altitude during operation relating to sea level	30 0
Annuae aumiu oberanon relaima to sea level	
Installation altitude above sea level, max.	3 000 m; Restrictions for installation altitudes > 2 000 m, see manual

Dimensions		
Width	20 mm	
Height	73 mm	
Depth	58 mm	
Weights		
Weight, approx.	45 g	
Other		
Data for selecting a voltage transformer		
<ul> <li>Secondary side, max.</li> </ul>	300 V	

last modified: 12/28/2021 🖸