SIEMENS

Data sheet

6ES7513-1RM03-0AB0



SIMATIC S7-1500R, CPU 1513R-1PN, central processing unit with work memory 600 KB for program and 2.5 MB for data, 1st interface: PROFINET RT with 2-port switch, SIMATIC Memory Card required **** approvals and certificate according to entry 109815625 at support.industry.siemens.com to be observed! ****

General information	
Product type designation	CPU 1513R-1 PN
HW functional status	FS01
Firmware version	V3.0
Product function	
 I&M data 	Yes; I&M0 to I&M3
 Isochronous mode 	No
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.73 A
Current consumption, max.	0.87 A
Inrush current, max.	1.15 A; Rated value
l²t	0.5 A ² ·s
Power loss	
Power loss, typ.	7.5 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	600 kbyte
 integrated (for data) 	2.5 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	50 ns
for word operations, typ.	64 ns

for fixed point arithmetic, typ.	85 ns
for floating point arithmetic, typ.	340 ns
CPU-blocks	
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	Number range: 1 to 59 999
• Size, max.	2.5 Mbyte; For non-optimized block accesses, the max. size of the DB is
	64 KB
FB	
Number range	0 65 535
• Size, max.	600 kbyte
FC • Number range	0 65 535
Size, max.	600 kbyte
OB OB	
• Size, max.	600 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
 Number of delay alarm OBs 	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 10 ms
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
 Number of startup OBs 	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
 Number of diagnostic alarm OBs 	1
Nesting depth	
 per priority class 	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	0.040
Number Detentivity	2 048
Retentivity — adjustable	Yes
IEC timer	165
Number	Any (only limited by the main memory)
Retentivity	Any (only innice by the main memory)
— adjustable	Yes
Data areas and their retentivity	
	256 kbyte; in total; available retentive memory for bit memories, timers,
Retentive data area (incl. timers, counters, flags), max.	counters, DBs, and technology data (axes): 216 KB
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	2 048; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte

— Outputs (volume)	8 kbyte
Subprocess images	
 Number of subprocess images, max. 	32
Hardware configuration	
Number of distributed IO systems	1
Number of IO Controllers	
• integrated	1
Rack	
 Modules per rack, max. 	1; CPU
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
supported	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	1
1. Interface	
Interface types	Voo: V1
RJ 45 (Ethernet)Number of ports	Yes; X1 2
integrated switch	Z Yes
Protocols	les
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	No
SIMATIC communication	Yes; Only Server
Open IE communication	Yes
Web server	No
Media redundancy	Yes
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes
— Number of connectable IO Devices, max.	64
— Updating times	The minimum value of the update time also depends on communication
	share set for PROFINET IO, on the number of IO devices, and on the
	quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
Autocrossing	Yes
 Industrial Ethernet status LED 	Yes
Protocols	
PROFIsafe	No
Number of connections	
Number of connections, max.	88
 Number of connections reserved for ES/HMI/web 	10
Redundancy mode	
 PROFINET system redundancy (S2) 	Yes
 PROFINET system redundancy (R1) 	No
Media redundancy	
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
 — MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0

MBBD	No
— MRPD	
 Switchover time on line break, typ. Number of stations in the ring, max 	200 ms; PROFINET MRP 50; Only 16 are recommended, however
 — Number of stations in the ring, max. SIMATIC communication 	so, Only to are recommended, nowever
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
• S7 routing	No
 S7 communication, as server 	Yes
 S7 communication, as client 	No
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
- several passive connections per port,	Yes
supported	
 ISO-on-TCP (RFC1006) 	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; max. 78 multicast circuits
• DHCP	No
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	No
	No
HTTPS OPC UA	No
OPC UA Client	No
OPC UA Server	No
Further protocols	NU
MODBUS	Yes; MODBUS TCP
S7 message functions	
or message ranedons	
	22
Number of login stations for message functions, max.	32 Xas
Number of login stations for message functions, max. Program alarms	Yes
Number of login stations for message functions, max.	Yes 5 000; Program messages are generated by the "Program_Alarm"
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering)	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission (Team Engineering) Status block	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 8 Ves; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 8 Ves; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. — of which control variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 700 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — Diwitables • Number of variables • Number of variables, max. — Diagnostic buffer	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job 200; per job 200 Yes Peripheral inputs/outputs 200
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job 200; per job 200 Yes Peripheral inputs/outputs 200
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which of variables, max. — of which of variables, max. — of which of variables, max. — of which powerfail-proof	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job 200; per job 200; per job 200; Peripheral inputs/outputs 200 Yes
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which of variables, max. — of which of variables, max. — of which of variables, max. — of which powerfail-proof Traces	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 700 700 700 700 700 700 7
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which powerfail-proof Traces • Number of configurable Traces	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; Pe
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of program alarms • Number of alarms for system diagnostics Test commission functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which powerfail-proof Traces • Number of configurable Traces • Memory size per trace, max.	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 700 700 700 700 700 700 7
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which powerfail-proof Traces • Number of configurable Traces	Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 No Yes; up to 8 simultaneously No 8; Breakpoints are only supported in RUN-Solo status Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; Pe

	Vec
	Yes
	Yes
MAINT LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	No
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	Yes
High-speed counter	No
Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	-30 °C
 horizontal installation, max. 	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
• vertical installation, min.	-30 °C
 vertical installation, max. 	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
User program protection/password protection	Yes
Copy protection	No
Block protection	Yes
Access protection	Vee
 protection of confidential configuration data 	Yes
Password for display	Yes
Protection level: Write protection	Yes
Protection level: Read/write protection	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header • lower limit	adjustable minimum cycle time
upper limit	adjustable minimum cycle time adjustable maximum cycle time
	สนุนจิเลมต์ แลงแทนแท บรูปตี แทย
Dimensions	05 mag
Width	35 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	336 g
last modified:	1/18/2023 🖸